



FABPANEL™ 150+ 7 Cores

1245 mm Wide
Cover = 25 mm

Fire = 60 minutes
Topping = 100 mm

T +27 11 706 4560
F +27 11 463 5589
134 Eccleston Crescent, Bryanston, Sandton
PO Box 364 Paulshof 2056
www.concreteslabs.co.za
slabs@iafrica.com

Designed to Eurocodes and EN1168

SECTION

Hollow core slab	FabPanel 150+	N° Cores	7	$A_b =$	1799.7 cm ²	$A_n/A_b =$	63.2%
	$b_{mod} =$	1250 mm		$A_n =$	1136.9 cm ²	$A_{jnt} =$	73.0 cm ²
	$h_p =$	150 mm		$I_{yc} =$	30438.9 cm ⁴	$e_{zt} =$	73.68 mm
Support depth	70 mm			$b_w =$	303.1 mm	$e_{zb} =$	76.32 mm
Topping	100 mm			$A_{top} =$	1250.00 cm ²		

MATERIALS

Concrete

Hollow core slab	C50	Code ref.	EN206-1		
In situ joint/topping	C30	Density	2400 kg/m ³	Aggregate	Limestone
		Density	2400 kg/m ³	Aggregate	Quartzite

Prestressing reinforcement

				Code ref.	EN10138		
Type	Diam. (mm)	A_p (mm ²)	Grade	f_{pk} (N/mm ²)	$f_{p0.1k}$ (N/mm ²)	E_p (N/mm ²)	$F_{p0.1k}$ (kN)
S7	Ø9.53	54.8	Y1860	1860	1674	201000	91.8
S7	Ø12.7	98.7	Y1860	1860	1674	201000	165.2

S7 = 7-wire strand

Prestressing of <u>top</u> reinforcement	70%	• f_{pk}		
Prestressing of <u>bottom</u> reinforcement	70%	• f_{pk}		
Concrete cover on <u>bottom</u> reinforcement	25 mm	$\Delta c =$	0 mm	

Mild reinforcement

				Code ref.	EN10080		
Type	Diam. (mm)	A_s (mm ²)	Grade	f_{uk} (N/mm ²)	f_{yk} (N/mm ²)	E_s (N/mm ²)	
RB	N/A	N/A	B500	550	500	200000	

RB = Ribbed bar

UTILITY FEATURES

User Category :	A	Domestic and residential areas
Exposure class :	XC1	
Fire resistance :	60 min.	

DESIGN FACTORS

Load safety factors

Permanent load :	$\gamma_g =$	1.35
Variable load :	$\gamma_q =$	1.50

Combination factors

$\psi_0 =$	0.7
$\psi_1 =$	0.5
$\psi_2 =$	0.3

DEFLECTION CRITERIA

Total long term deflection: variable load	with $\psi_2 =$	30%	
$UZ < L /$	250	loads = $SW_{slab} + SW_{top} + \Sigma PL + \psi_2 \cdot \Sigma VL$	SW = self weight
Additional long term deflection: variable load	with $\psi_2 =$	30%	PL = permanent load
$\Delta UZ < L /$	500	loads = $\Sigma PL + \psi_2 \cdot \Sigma VL$	VL = variable load

slabs@iafrica.com
T +27 11 706 4560

134 Eccleston Crescent, Bryanston, Sandton
PO Box 364 Paulshof 2056

Service is not our only strength.





FABPANEL™ 150+ 7 Cores

1245 mm Wide
Cover = 25 mm

Fire = 60 minutes
Topping = 100 mm


T +27 11 706 4560
F +27 11 463 5589
134 Eccleston Crescent, Bryanston, Sandton
PO Box 364 Paulshof 2056
www.concreteslabs.co.za
slabs@iafrica.com

Designed to Eurocodes and EN1168

This Load Span Table is for guidance only and should not be considered as a complete calculation.

Reinforcement type	STR 01	STR 02								
Top reinforcement		2xØ9.53								
Bottom reinforcement	6xØ9.53	8xØ9.53								
Reinforcement (kg/m ²)	2.07	3.46								
M _{Rd} (kNm/m)	87.1	121.4								
V _{nc,Rd} (kN/m)	61.2	66.1								
V _{c,Rd} (kN/m)	60.3	78.5								

Permanent load g (kN/m ²)	Variable load q (kN/m ²)	CLEAR SPAN (IN METERS)												
1.50	1.50	9.48	9.73											
1.50	2.00	9.26	9.67											
1.50	2.50	8.86	9.61											
1.50	3.00	8.51	9.49											
1.50	3.50	8.20	9.29											
1.50	4.00	7.91	9.13											
1.50	5.00	7.43	8.77											
1.50	6.00	7.02	8.29											
1.50	7.00	6.68	7.88											
1.50	8.00	6.38	7.53											
1.50	9.00	6.14	7.22											
1.50	10.00	5.88	6.95											
1.50	12.50	5.40	6.27											
1.50	15.00	5.02	5.49											
1.50	20.00	4.18	4.43											



SECTION - self weight

Precast slab :	2.14	kN/m ²			
Joint :	0.14	kN/m ²	--> Sum =	2.28	kN/m ² (slab + joint)
Topping :	2.35	kN/m ²	--> Sum =	4.63	kN/m ² (slab + joint + topping)

UTILITY FEATURES

User Category :	A	Domestic and residential areas
Exposure class :	XC1	Fire resistance : 60 min.

DEFLECTION CRITERIA

- Long term part of variable load $\psi_2 = 0.3$
- Long term TOTAL deflection under self weight of the slab + total permanent load + 30% of the variable load $< L / 250$
 - Long term ADDITIONAL deflection under total permanent load + 30% of the variable load $< L / 500$



FABPANEL™ 150+ 7 Cores

1245 mm Wide
Cover = 25 mm

Fire = 60 minutes
Topping = 100 mm


T +27 11 706 4560
F +27 11 463 5589
134 Eccleston Crescent, Bryanston, Sandton
PO Box 364 Paulshof 2056

www.concreteslabs.co.za
slabs@iafrica.com

Designed to Eurocodes and EN1168

This Load Span Table is for guidance only and should not be considered as a complete calculation.

Reinforcement type	STR 01	STR 02								
Top reinforcement		2xØ9.53								
Bottom reinforcement	6xØ9.53	8xØ9.53								
Reinforcement (kg/m ²)	2.07	3.46								
M _{Rd} (kNm/m)	87.1	121.4								
V _{nc,Rd} (kN/m)	61.2	66.1								
V _{c,Rd} (kN/m)	60.3	78.5								



MATERIALS

Concrete	Precast slab :	C50	Density =	2400	kg/m ³		
	Joint/Topping :	C30	Density =	2400	kg/m ³		
Prestressing steel	Strand Ø9.53	Y1860	f _{pk} =	1860	N/mm ²	f _{p0.1k} =	1674 N/mm ²
	Strand Ø12.7	Y1860	f _{pk} =	1860	N/mm ²	f _{p0.1k} =	1674 N/mm ²
	Prestressing of <u>top</u> reinforcement		70%		• f _{pk}		
	Prestressing of <u>bottom</u> reinforcement		70%		• f _{pk}		
	Concrete cover on <u>bottom</u> reinforcement		25	mm	Δc =	0	mm

SECTION - self weight

Precast slab :	2.14	kN/m²			
Joint :	0.14	kN/m²	--> Sum =	2.28	kN/m² (slab + joint)
Topping :	2.35	kN/m²	--> Sum =	4.63	kN/m² (slab + joint + topping)

UTILITY FEATURES

User Category :	A	Domestic and residential areas
Exposure class :	XC1	Fire resistance : 60 min.

DEFLECTION CRITERIA

- Long term part of variable load $\psi_2 = 0.3$
- Long term TOTAL deflection under self weight of the slab + total permanent load + 30% of the variable load < L / 250
 - Long term ADDITIONAL deflection under total permanent load + 30% of the variable load < L / 500